



718 S. Michigan Howell, MI 48843

### WATER ANALYSIS RESULTS

To: Village of Stockbridge  
 PO Box 155  
 Stockbridge, MI 49285

Date Sampled: 8/14/2020 7:30  
 Date Received: 8/17/2020  
 Collected By: Matt T  
 Sample Point: 348 Poplar

Sample ID: Columbia Lakes  
 WSSN 1565

Lab Sample Number: 136390-02

Test Parameter	Result	Units	RL	Method	Analysis Date	Maximum Desired Limit
Total Copper	0.019	mg/L	0.01	EPA200.8	8/18/2020 0:00	1.3
Total Lead	Not Detected	mg/L	0.001	EPA200.8	8/18/2020 0:00	0.015

Released By: 

Date: 8/24/2020

Laboratory #23 assigned by the Michigan Department of Environmental Quality for the microbiological and chemical analysis of drinking water.

**ABBREVIATIONS:**

- RL = Lowest reporting level
- MCL = Maximum Contaminant Level - The maximum permissible level established by the USEPA and or MDEQ for safe drinking water.
- SMCL = Secondary Maximum Contaminant Level - Suggested maximum level established by the USEPA for desirable water quality.
- CFU/100 ml = Colony Forming Units/100 milliliter sample volume.
- mg/L = Milligrams per liter (= parts per million).

Test Parameter	Result	Units	RL	Method	Analysis Date	Maximum Desired Limit
Total Copper	0.019	mg/L	0.01	EPA200.8	8/18/2020 0:00	1.3
Total Lead	Not Detected	mg/L	0.001	EPA200.8	8/18/2020 0:00	0.015